ILECO I
ILOILO I ELECTRIC COOPERATIVE, INC.

BID BULLETIN 2026-030

SUPPLY AND DELIVERY OF DISTRIBUTION TRANSFORMERS

Date & Time : November 3, 2026, at 8:30 A.M.
To : All Concerned Bidders
From : Bids and Awards Committee (BAC)
Subject : Amendments/Supplemental to the Bidding Documents

Please be informed of the following amendments/supplemental to the bidding documents. This shall replace/supersede all related statements/paragraphs made in the provided bidding documents.

REFERENCE	SECTION/ITEM NUMBER	REFERENCE	AMENDMENT/MODIFICATION/ CLARIFICATION	REMARKS
A. LEGAL DOCUMENTS: Folder 1 (ENVELOPE 1)	***Omnibus Sworn Statement***		***Must be Notarized***	***Disqualification for non-compliance***
	Proof of VAT payments for the past 6 months		***April 2026- September 2026***	***Disqualification for non-compliance***
	Tax Clearance		***Valid during bid opening and contract signing of winning bidder.***	***Disqualification for non-compliance***
	A certification under oath from the bidder's responsible officers that the bidder is free and clear of all liabilities with the government		***Must be Notarized***	***Disqualification for non-compliance***
	Duly signed and Notarized Instructions to Bidders	***Instructions to Bidders***	***Pages 6-35. Signed in every page and notarized on the last/separate page***	***Disqualification for non-compliance***
B. TECHNICAL DOCUMENTS: Folder 2 (ENVELOPE 1)	***Statement in matrix form of all its ongoing and completed government and private contracts***		***Relevant Period: October 2023 – October 2026***	***Disqualification for non-compliance***
	Statement identifying the bidder's Single Largest Completed Contract (SLCC)		***Similar to the contract to be bid. At least 50% of the ABC.*** ***Relevant Period: October 2023 – October 2026***	***Disqualification for non-compliance***
D. TECHNICAL PROPOSAL: Folder 1 (ENVELOPE 2)	***Conforming Technical Specification***	***Brochure***	***Bring Brochures during bid opening***	***Disqualification for non-compliance***

<table>
<tr><th>REFERENCE</th><th>SECTION/ITEM NUMBER</th><th>REFERENCE</th><th>AMENDMENT/MODIFICATION/ CLARIFICATION</th><th>REMARKS</th></tr>
<tr><td></td><td>Conforming Technical Specification</td><td>Sample</td><td>Sample of terminal cover or material used to manufacture the cover</td><td>Disqualification for non-compliance</td></tr>
<tr><td></td><td>Conforming Technical Specification</td><td>Sample</td><td>One (1) sample of terminal bushing, for both primary and secondary bushings of any rating</td><td>Disqualification for non-compliance</td></tr>
<tr><td></td><td>Conforming Technical Specification</td><td></td><td>Bidders must submit a certification from manufacturer for the country of Origin</td><td>Disqualification for non-compliance</td></tr>
<tr><td></td><td>Conforming Technical Specification</td><td>Conduct Factory and Acceptance Test (FAT)</td><td>Maximum of four (4) personnel to conduct Factory and Acceptance Test</td><td>Disqualification for non-compliance</td></tr>
<tr><td></td><td>Conforming Technical Specification</td><td></td><td>Bidders must submit at least three (3) Certification of Good Performance from other DUs</td><td>Disqualification for non-compliance</td></tr>
<tr><td></td><td>Conforming Technical Specification</td><td></td><td>Soft copy of illustration of transformers will be sent</td><td></td></tr>
<tr><td></td><td></td><td><table><tr><td>Low Voltage (LV side)</td><td></td></tr><tr><td>• BIL (Full Wave, Crest):</td><td>30 kV</td></tr><tr><td>•Chopped Wave, Crest:</td><td>33 kV</td></tr><tr><td>•Flashover Time:</td><td>≥1.0 µs</td></tr><tr><td>•Applied Voltage Test:</td><td>34 kV rms</td></tr><tr><td>•Induced Voltage Test:</td><td>17 kV rms</td></tr><tr><td>•Percent Impedance:</td><td>2.0 ± 10% (15–50 kVA)</td></tr></table></td><td><table><tr><td>Low Voltage (LV side)</td><td></td></tr><tr><td>• BIL (Full Wave, Crest):</td><td>30 kV</td></tr><tr><td>•Chopped Wave, Crest:</td><td>33 kV</td></tr><tr><td>•Flashover Time:</td><td>≥1.0 µs</td></tr><tr><td>•Applied Voltage Test:</td><td>10 kV rms</td></tr><tr><td>•Induced Voltage Test:</td><td>1.4 kV rms</td></tr><tr><td>•Percent Impedance:</td><td>2.0 ± 10% (15–50 kVA)</td></tr></table></td><td>Disqualification for non-compliance</td></tr>
<tr><td></td><td>Conforming Availability of Stocks</td><td></td><td>25 % of each item. To be confirmed during Post Qualification</td><td>Disqualification for non-compliance</td></tr>
</table>

For guidance and information of all concerned.

BIDS AND AWARDS COMMITTEE
Iloilo 1 Electric Cooperative Inc. (ILECO 1)

ATTY. ANTONIE C. COLLANTES, CPA
BAC Chairperson

BAC BID BULLETIN 2026-030: Supply and Delivery of Distribution Transformers